

**CITY OF SAN ANTONIO
Development Services Department
MEMORANDUM**

TO: DSD Associates
FROM: Roderick Sanchez, Director and Building Official
DATE: April 11, 2011
FILE: Code Interpretation Manual

INTERPRETATION NUMBER: CI2011-003

TITLE: Residential Exterior Door Requirements in the Military Sound Attenuation Overlay

CODE EDITION: COSA Unified Development Code (UDC), Chapter 35

SECTION: Section 35-339.05(c)B.4.

QUESTION: Do the following types of exterior doors on residential structures (e.g., one- and two-family dwellings, townhomes, etc.) meet the City requirements for exterior doors in the Military Sound Attenuation Overlay as described in the above referenced UDC code section?

- Solid wood doors;
- Steel doors with a foam core;
- Wood doors with STC-rated glass as listed in the UDC

ANSWER: Yes.



Roderick J. Sanchez, A.I.C.P., C.B.O.
Director and Building Official
Development Services Department