



## DEVELOPMENT SERVICES

---

**TO:** DSD Associates

**FROM:** Amin Tohmaz, PE, CBO, Director and Building Official

**DATE:** April 17, 2026

---

**INTERPRETATION NUMBER: CI2026-001**

**TITLE:** Clarification of distance measurement between off premise signs

**CODE EDITION:** Chapter 28 Signs and Billboard Ordinance

**SECTIONS:** Section 28-54

**PURPOSE:** Define spacing requirements between new off premise digital display signs and other off premise signs.

**QUESTION:** How is the distance measured between a new off-premises digital sign and other off-premise signs in the vicinity?

**ANSWER:** The measurement of the distance between an off-premise digital sign and a second off premise sign shall be:

- (1) An off-premises digital sign may not be within two thousand (2000) feet of another off-premise digital sign facing the same traveled way. An off-premise digital sign may not be in a line of sight with another off-premise digital sign;  
or
- (2) An off-premises digital sign may not be within fifteen hundred (1500) feet of an off-premise sign facing the same traveled way.

The applicant is responsible for providing a survey to verify compliance of the distance measurement between the proposed off-premise digital sign and any other signs.

*Amin Tohmaz*

---

Amin Tohmaz, P.E., C.B.O.  
Director and Building Official  
Development Services Department